

TAMILNADU FIRE AND RESCUE SERVICE

SCHOOL NO OBJECTION CERTIFICATE

R.C.NO:505/V/SPR/2023

DATED:20/06/2023

Certificated that the M/s.SREE SHANTHI ANAND VIDYALAYA, at No. 509, Thirumudivakkam Road, Thirumudivakkam, Sriperumbudur Taluk, Kanchipuram District. comprised of Ground Floor and 1 (upper floors) occupied by M/s. SREE SHANTHI ANAND VIDYALAYA have Fire Service Rules, and verified by the officer concerned of Fire Service on 20.06.2023 in the presence of Principal, On 17.06.2023 M/s.SREE SHANTHI ANAND VIDYALAYA (G+1), No. 509, Thirumudivakkam Road, Thirumudivakkam, Sriperumbudur Taluk, Kanchipuram District and that the building / premises is for occupancy class School Premises with effect from 20.06.2023 for a period of 19.06.2024 Years in accordance with rule and subject to compliance of the conditions.

CONDITIONS

1. This License is valid for One year from the date of issue.
2. Fire Safety Systems should be maintained in good working condition.
3. Mock drill to be conducted periodically with the help of local fire brigade.
4. Any erection of permanent or temporary structure should be intimated to this department.
5. Further to limit the occupant load and to ensure better fire and life safety measures the

Following additional measures are insisted.

6. a). Building occupancy capacity should not be more than 4 people per Sq. meter as per The National Building Code-2016.
- b). The staircase treads and flooring shall be treated with rough finish (Grooving) to Avoid falling of children.
- c). As per Para 6.3 of the BIS Standards IS 14435:1997 as the Classrooms have only One entrance, the capacity of the class room shall have to be limited to 45 students.

TO:

M/s.Sree Shanthi Anand Vidyalaya,
No:509, Thirumidivakkam Road, Thirumudivakkam,
Sriperumbudur Taluk, Kanchipuram District.

சி.ஆர்.செனி
20-06-2023
நிலைய அலுவலர்
தீயணைப்பு - மீட்புப்பணி நிலையம்
திருப்பெரும்புதூர்.

Copy to :District officer, Kanchipuram.